



1 **EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

- 3 EC - Type Examination Certificate Number: **Baseefa03ATEX0222**
- 4 Equipment or Protective System: **SM87 BEACONS**
- 5 Manufacturer: **MEDC LIMITED**
- 6 Address: **Colliery Road, Pinxton, Nottingham, NG16 6JF**

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Baseefa (2001) Ltd. Notified body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. **03(C)0265**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014: 1997 + Amendments 1 & 2 EN 50018: 2000 + Amendment 1 EN 50281-1-1: 1998

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

(Ex) II 2 GD EEx d IIC T* (see schedule)

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa (2001) Ltd. Customer Reference No. **0676**

Project File No. **03/0265**

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

Baseefa (2001) Ltd.

Health and Safety Laboratory Site, Harpur Hill,
Buxton, Derbyshire SK17 9JN
Telephone +44 (0) 1298 28255 Fax +44 (0) 1298 28216
e-mail info@baseefa2001.biz web site www.baseefa2001.biz
Registered in England No. 4305578 at 13 Dovedale Crescent, Buxton,
Derbyshire, SK17 9BJ

R S SINCLAIR
DIRECTOR
On behalf of
Baseefa (2001) Ltd.



13

Schedule

14

Certificate Number Baseefa03ATEX0222

15 Description of Equipment or Protective System

The Type SM87 Beacons each comprise a cylindrical enclosure on a square base with a domed glass cover secured by 4 off M6 x 12mm long socket head cap screws of grade A4-80 stainless steel. The base and cover ring may be manufactured from either aluminium or stainless steel.

The interior of the units may contain one of the following lamp types and the associated control gear, each with different designations and thermal characteristics as shown below :-

TYPE SM87 ---	Lamp Type	Voltage (V)	Watts (W)	Temperature Classification T* (T _{amb} = -55°C to + °C)			
				+40°C	+55°C	+70°C	+85°C
LU3	Filament	240 ac	48	T135°C	T200°C	N/A	
LU1	Fluorescent	254 ac	10	T100°C	T135°C	N/A	
		240 ac		5	T85°C		
		110/120 ac	T85°C				
		12, 24, 48 dc					
HXB	Xenon	110, 240, 254 ac	11	T85°C	T135°C	T135°C	N/A
		12, 24, 30, 48 dc					
XBT/A	Xenon (Electronics unit)	110, 240, 254 ac	11*	T85°C	T135°C	N/A	
		12, 24, 30, 48 dc					
XBT/B	Xenon (Lamp unit)	N/A		N/A		T135°C	
LED	LED	24, 48 dc	4	T85°C	T135°C	N/A	
	LED (Blue)		5.6				

* Note XBT units A & B are intended to be used together in pairs and are rated accordingly

The enclosure is provided with internal and external earth connection facilities.

Up to 4 cable entry holes threaded M20 to M25 (or NPT & Pg equivalents) are provided for the accommodation of suitable BASEEFA certified flameproof IIC cable entry devices, with or without the interposition of a suitable BASEEFA certified flameproof IIC thread adapter. Unused entries are to be fitted with suitable BASEEFA certified flameproof IIC stopping plugs.

Suitable flameproof IIC cable entry devices, thread adapters and stopping plugs certified as Equipment (not a Component) under an EC Type Examination Certificate to Directive 94/9/EC may also be used in the manner specified above.

If the unit is intended for use in a dust atmosphere these devices must be sealed in accordance with the relevant codes of practice to ensure a dust tight seal.

In addition, these units may be supplied by the manufacturer in an assembly of up to five interconnected enclosures.

16 Report Number

Baseefa Certification Report No. 03(C)0265



17 Special Conditions for Safe Use

None

18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 Drawings and Documents

Number	Issue	Date	Description
562-131 Sheets 1 to 3	A	26-03-03	General Arrangement, SM87 Beacons
562-130	A	28-02-03	Enclosure, Earth & Seal Detail
562-128	A	25-03-03	Cover, Machining Detail, Stainless Steel
562-129	A	25-03-03	Enclosure & Cover Detail, Aluminium
562-127	A	25-03-03	Enclosure, Machining Detail, Stainless Steel
562-132	A	26-03-03	Circuit Diagram, SM87 HXB 240V, High Power
562-133	A	26-03-03	Circuit Diagram, SM87 HXB 240V
562-134	A	23-03-03	Circuit Diagram, SM87 HXB 110/120V
562-135	A	27-03-03	Circuit Diagram, SM87 HXB 254V
562-136	A	27-03-03	Circuit Diagram, SM87 HXB 24V
562-137	A	26-03-03	Circuit Diagram, SM87 HXB 48V
562-138	A	26-03-03	Circuit Diagram, Relay/Telephone Interface
562-139	A	26-03-03	Circuit Diagram, SM87 Fluorescent 12, 24 & 48V
562-140	A	26-03-03	Circuit Diagram, SM87 LED 24V
562-141	A	26-03-03	Circuit Diagram, SM87 LED 48V
562-142	A	26-03-03	Circuit Diagram, SM87 LED (Blue) 24 & 48V
562-143	A	26-03-03	Circuit Diagram, SM87 HXB 12V
562-144	A	26-03-03	Circuit Diagram, SM87 HXB 30V